



TÜRK STANDARTLARI ENSTİTÜSÜ
TURKISH STANDARDS INSTITUTION

TSE DENEY VE KALİBRASYON MERKEZİ BAŞKANLIĞI
ELEKTROTEKNİK LABORATUVARI GEBZE MÜDÜRLÜĞÜ
HEADSHIP OF TSE TEST AND CALIBRATION CENTER
ELECTROTECHNICAL LABORATORY GEBZE DIRECTORATE



**CLASSIFICATION OF REACTION TO FIRE
FOR ELECTRIC CABLES
IN ACCORDANCE WITH EN 13501-6**

Sponsor	:	REÇBER KABLO SANAYİ VE TİCARET LİMİTED ŞİRKETİ
Trade mark	:	REÇBER
Model	:	Cable J-Y(St)...Lg
Product description	:	CLASS 1 MONO COPPER-MULTICORE UNARMoured
Standard applied	:	TS EN 50575/A1:2016
Regulation	:	Construction Products Regulation (305/2011/EU)
Notified Body No	:	1783
Issue Number	:	352552
Date of Issue	:	27.07.2017

Reaction to Fire Class: E_{ca}

Seal	Person in charge of tests	Approved by
BA / 07 / 2017	Serdar GENÇ Electronic Technician	Hilmi AKDOĞAN Laboratory Director

Note: This classification document does not represent type approval or certification of the product. The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 attestation of conformity and CE marking under the Construction Products Regulation. The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested. This document consists of 2 pages. This report can't be partially copied and the unsigned copies are invalid.



1- Introduction

This classification report defines the classification of cable below in accordance with the procedures given in TS EN 13501-6

2- Details of classified product

Sponsor	REÇBER KABLO SANAYİ VE TİCARET LİMİTED ŞİRKETİ	
Manufacturer (if different)		
Place of Manufacturer	TÜRKGÜCÜ KÖYÜ YOLU ÜZERİ YILMAZ ALPASLAN CAD. 4.KM NO:73 PK:59850 ÇORLU-TEKİRDAĞ	
Sample description		
Trade name, Type of cable	REÇBER, Cable J-Y(St)...Lg	
Sample description	CLASS 1 MONO COPPER-MULTICORE UNARMoured	
Tested cable and size and overall diameter	1- J-Y(St)Y...Lg 1x2x0,80mm+0,40 mm 2- J-Y(St)Y...Lg 4x2x1,5mm ² +0,80 mm	5,30 mm 13,20 mm

3- Test Reports in support of this classification

Enter details of reports here as applicable

Number	Test reports no and Date	Test methods
1	352550/ 07-17	TS EN 60332-1-2/A11:2017
2	352547/ 07-17	TS EN 60332-1-2/A11:2017

4- Classification and field of application

The format of the reaction to fire classification for electric cables is:

Fire Behaviour	Smoke Production	Flaming Droplets	Acidity
Eca	-	-	-

Reaction to Fire Classification: **Eca**

5- Field of Application

This classification is valid for the power cables listed below as determined in the extended application process according to CLC-FprTS 50576-2016.

Trade name	Cable Family	Outer diameter of cable	Reaction to Fire Classification
REÇBER	J-Y(St)Y...Lg	From 5,30 mm to 13,20 mm	Eca

